

SGWA
Swiss Gas and Water
Industry Association
Grütlistrasse 44
CH- 8027 Zürich

Certification body water



Certificate No.: 2011-6994

Certificate holder: Integra Metering, 12 rue Font Grasse, FR-31700 Blagnac

In accordance with our regulation ZW101 „general terms and conditions of the SGWA certification body water“ the SGWA certify the following serial products:

Rubric: Water meters
Denomination: RUBIN® SONIC (RSO)
Types: RUBIN® SONIC (RSO)

DN: 50...200 PN: 10/16 tmax: 50 °C

Certification Standard: SGWA ZW108 (01/19), EN ISO 4064

Validity: 31.03.2026

Conditions (C) / Remarks (R):
None

The applicant is entitled to offer the above mentioned products as certificated by the SGWA and to use the above SGWA-conformity mark (publication in the list of certificates water).



accredited according to
SN EN ISO/IEC 17065

Swiss Gas and Water Industry Association
Certification body water


Javier Fernandez
Head

Zurich, 02.08.2021

Rubric: Water meters

Denomination: RUBIN® SONIC (RSO)

Types	DN	PN	C°	Acoustic group	Losses kWh/24 h / ErP Class	Content	Index	Metrology
RUBIN SONIC, Q3 = 40 m³/h	50	16	50	-	-	-	-	R500 (H/V)
RUBIN SONIC, Q3 = 63 m³/h	65	16	50	-	-	-	-	R500 (H/V)
RUBIN SONIC, Q3 = 63 m³/h	80	16	50	-	-	-	-	R500 (H/V)
RUBIN SONIC, Q3 = 100 m³/h	100	16	50	-	-	-	-	R500 (H/V)
RUBIN SONIC, Q3 = 150 m³/h	125	16	50	-	-	-	-	R500 (H/V)
RUBIN SONIC, Q3 = 250 m³/h	150	16	50	-	-	-	-	R500 (H/V)
RUBIN SONIC, Q3 = 400 m³/h	200	10/16	50	-	-	-	-	R500 (H/V)

H = horizontal; V = vertical